

Subject: Approved Condensers

Condenser coils in certain rack condensing units have been approved for use with Scotsman Remote cooled cube ice equipment. They include:

- Bohn G or X series: MAC4XS6C; MAC7XS6C or MAC8XS6C
- Master Bilt: R62R1104C; R62R1104CC; R62R1103C; R62R1105C

Conditions

- The condenser coil must NOT have been connected to an R-502 or R-22 system.
- A head pressure control valve, like a headmaster, must be added. Scotsman's kit for the above is RCKCME6GX

Eclipse condensing units

- The condenser coil must NOT have been connected to an R-502 or R-22 system.
- Only the condenser coil part of the rack has been approved. Use of the Eclipse CP is mandatory. If connecting an Eclipse CP compressor pack to one of the above, a head pressure control valve is NOT needed.